

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE

No. 01/2023

DATE. 22/01/23

It is certified that an Inspection team headed by Dr. Ravindra Singh

(Name of officers with designation)

From CHC, Sitarganj (U.S.M)

(Name of department/ Office) in pected the The Wilbur School

Eldico, Sidel, Sitarganj (Name & Address of the

School) on _____ and found that the the Wilbur School,

Eldico, Sidel, Sitarganj (Name of School) has safe drinking water

facilities for the students and members of staff of the institution and is maintaining the hygienic

sanitation condition in the school building & the campus as per the norms prescribed by the


Central/State/U.T Govt.

The above valid for a period of 2 yrs

Signature with Seal : _____

Name : _____

Designation : _____


चिकित्साधिकारी
स्वा.केन्द्र सितारगंज
Dr. Ravindra Singh
कचम सिंह
Medical officer

To

The Wilbur School

Eldico, Sidel, Sitarganj

(Name & Address of the Institution)



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Rudrapur U.S.Nagar

E-mail: eeudmujs@gmail.com

Test Report ID: 61/UJS/USNWQTML/2023-24


WATER QUALITY TEST REPORT


Name and Address of Organization/ Customer	THE WILBUR SCHOOL Sidcul, Sitarganj U.S.Nagar, Uttarakhand		
Type of Source : Drinking Water	Sample Description:	One water Sample Collected campus Ro	
Reference Sample Identification:	DLWQTML/UJS/WS-01	Date of Start of Analysis: 02.06.2023 Date of End of Analysis : 06.06.2023	
Date of Sample Received: 02.06.2023	Sample Collected by:	Customer	

S.No.	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS)
1	Colour	Less than 5	5	15
2	Odour	Unobjectionable	Unobjectionable	Unobjectionable
3	Taste	Agreeable	Agreeable	Agreeable
4	Total Dissolved Solids (TDS), mg/l max	90	500	2000
5	pH at 25°C	7.52	6.5 to 8.5	No Relaxation
6	Turbidity, NTU ma	0.41	1	5
7	Chloride, Mg/l max	5.9	250	1000
8	Total Alkalinity as CaCO ₃ mg/l max	63	200	600
9	Total Hardness as CaCO ₃ mg/l max	80	200	600
10	Calcium as Ca mg/l max	24	75	200
11	Magnesium as Mg mg/l max	4.86	30	100
Microbiological Test Parameters				
12*	E.Coli MPN /100ml	Absent	Absent	Absent
13*	Total Coliform/100ml	Absent	Absent	Absent

Note: 12* And 13* indicates parameters that are not NABL Accredited.

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.


Chemist


Technical Manager

Technical Manager
District Water Quality Testing
Monitoring Laboratory
Uttarakhand Jal Sansthan, U.S.Nagar

-End of Report -